

MATERIAL STANDARD**TAPE
COTTON, WOVEN, ELECTRICAL**

Cotton Woven Tape for electrical purposes shall be made from unbleached, undyed yarn in accordance with ASTM D 335, except as modified herein.

Rolls of tape shall be 36 yards in length with no more than one splice per roll, and shall be packaged 10 or 20 rolls to the carton. Each package shall be marked with the name of the supplier and the nominal dimensions of the tape.

Tape furnished under this specification is subject to inspection and test. All tests shall be made in accordance with ASTM D 259, Methods of Testing and Tolerances for Woven Tapes.

Reference Specifications: ASTM D 335, ASTM D 259, latest revisions.

Approved Manufacturers: Elizabeth Webbing Mills, Fiber Manufacturing Company,
Insulation Manufacturers Corporation, MAC Products.

Stock Unit: Roll

| Stock Number | Weave | Width Inches | Thickness Inches | Total Ends | Picks Per Ins. | Min. Yds. Per Lb. | Break. Str. Min. in Lbs. |
|--------------|-------|--------------|------------------|------------|----------------|-------------------|--------------------------|
| 736162 | Plain | 1/2 | 0.007 | 36 | 36 | 290 | 25 |
| 736166 | Plain | 3/4 | 0.007 | 56 | 36 | 190 | 30 |
| 736170 | Plain | 1 | 0.007 | 72 | 36 | 140 | 40 |

ORIGINATOR

Jim S. Horn

STANDARDS COORDINATOR

Charles L. Shaffer

STANDARDS SUPERVISOR

John C. Skinner

UNIT DIRECTOR

Betty Robm